



Associated  
Engineering

GLOBAL PERSPECTIVE.  
LOCAL FOCUS.

Date: April 3, 2018 File: 20142670.020.C.01.00

Owner: Town of Lake Cowichan

AE Rep.: Ann Stephenson, P.Eng.

Project: Water Main River Crossings

Subject: Addendum #1

## ADDENDUM

*The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the contractor or any subcontractor not being familiar with this addendum.*

1. **Information:** The Tender period has been extended. The new closing time and date are:

**Tender Closing Time: 2:00pm**

**Tender Closing Date: Friday, April 13, 2018**

The new deadline for questions or to proposed alternative cost saving measures is **Tuesday, April 10, 2018.**

2. **Question:** Please confirm the Pipe Class that would be required for the HDPE alternative.

**Answer:** Class 200, DR11 pipe would be suitable.

